NORTHERN LAKE SERVICE, INC.
Analytical Laboratory and Environmental Services
400 North Lake Avenue - Crandon, WI 54520
Ph: (715)-478-2777 Fax: (715)-478-3060

ANALYTICAL REPORT

WDNR Laboratory ID No. 721026460
WDATCP Laboratory Certification No. 105-330
EPA Laboratory ID No. WI00034

NLS Project: 183018
NLS Customer: 02130

Client: Bad River Water & Sewer Dept
Attn: Pat Hunt
Firehall
PO Box 39
Odanah, WI 54861 0039

Fax: 715 682 7775 Phone: 715 685 7878

Project: Bactis

Birch Hill NLS ID: 677873
COC: 142812:1 Matrix: DW
Collected: 08/14/12 09:33 Received: 08/15/12
Notes: Bottle received with Sodium Thiosulfate preservative.

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					08/15/12	SM 9223B	105330
E. coli	Negative					08/15/12	SM 9223B	105330
	Colilert Used							

Franks Fields NLS ID: 677874
COC: 142812:2 Matrix: DW
Collected: 08/14/12 09:49 Received: 08/15/12
Notes: Bottle received with Sodium Thiosulfate preservative.

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					08/15/12	SM 9223B	105330
E. coli	Negative					08/15/12	SM 9223B	105330
	Colilert Used							

New Odanah #1 NLS ID: 677875
COC: 142812:3 Matrix: DW
Collected: 08/14/12 10:30 Received: 08/15/12
Notes: Bottle received with Sodium Thiosulfate preservative.

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					08/15/12	SM 9223B	105330
E. coli	Negative					08/15/12	SM 9223B	105330
	Colilert Used							

New Odanah #2 NLS ID: 677876
COC: 142812:4 Matrix: DW
Collected: 08/14/12 10:00 Received: 08/15/12
Notes: Bottle received with Sodium Thiosulfate preservative.

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					08/15/12	SM 9223B	105330
E. coli	Negative					08/15/12	SM 9223B	105330
	Colilert Used							

Diaperville NLS ID: 677877
COC: 142812:5 Matrix: DW
Collected: 08/14/12 09:08 Received: 08/15/12

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					08/15/12	SM 9223B	105330
E. coli	Negative					08/15/12	SM 9223B	105330
	Colilert Used							